



- ### NOTES
- 1) LOCATE PIPE SUPPORT PENETRATION TO AVOID EXISTING UTILITIES AND/OR UTILITY SUPPORTS WHICH ARE NOT SHOWN.
 - 2) STEEL PIPE SHALL BE WITH ASDO GRADE B GALVANIZED AS PER WITH ASDO GRADE 230.
 - 3) MEMBRANE GROUT SHALL BE FIVE STAR INSTANT GROUT AS MANUFACTURED BY US GROUT CORP. OR APPROVED EQUAL.
 - 4) 'DETAIL A' IS FOR INFORMATION PURPOSES ONLY.
 - 5) ALL ROOFING DETAILS MUST BE APPROVED PRIOR TO CONSTRUCTION BY ROOFING MEMBRANE MANUFACTURER. TYPICAL ROOFING SYSTEM - DYNAMIT NOBEL 260 MAIN ST. SUITE 110 NORTH POST. LONG ISLAND NY 11769 (PHONE 516-734-9535) TO MAINTAIN THE ROOFING GUARANTEE.
 - 6) CONTRACTOR SHALL TAKE CARE NOT TO CUT OR DAMAGE EXISTING REINFORCEMENT DURING COREDRILLING.
 - 7) LIGHT GAUGE STEEL STRUT AND CONNECTING HARDWARE SHOWN ON DRAWING WITH MODEL NUMBER PREFIXED BY '184' SHALL BE UNISTRUT SYSTEM PARTS AS MANUFACTURED BY UNISTRUT CORPORATION OR AN APPROVED EQUAL.

